

**Date: Tuesday, August 25, 2015**

**ADDENDUM NO. 3  
to the  
Iowa Department of Transportation  
Proposal No. 14842  
For Electrical Upgrade to Newton Maintenance Garage  
Letting Date: 9/2/15**

**Notice To Bidders:**

This Addendum is issued to incorporate the following additions, deletions, corrections, and/or clarifications to the terms or specifications and shall hereby be considered a part of the final contract documents. This Addendum shall supersede, modify and/or change all statements to the contrary in the bid proposal and shall take precedence over previous terms or specifications.

**CHANGES TO THE DRAWINGS**

**1. Maintenance Facility Lighting**

See attached drawings D1 and E5 for lighting demolition plan and new lighting plan to correspond with the CHANGES TO THE SCOPE OF WORK section in Addendum #1.

Note: The quantity of fixtures has changed from Addendum #1 (refer to attached drawing E5).

Delete item #4 and item #5 from the CHANGES TO THE DRAWINGS section of Addendum #1. Refer to attached drawings D1 and E5 for lighting information.

Provide new lighting in the Maintenance Garage as shown on the attached drawings and described in Addendums #1 and Addendums #2.

**2. Sheet E2 – Electrical Plan**

Clarification: The background floor plan shown on this sheet is a scanned image of the original electrical plans. Any grayed out receptacles, equipment, or notes shown within the floor plan background are part of the original electrical plans and are not part of this contract.

**3. Sheet E3 – Electrical Details**

Provide TVSS units, TVSS-1 & TVSS-2, on the Enclosed Circuit Breaker and on Panel P1 respectively.

Refer to the TVSS schedule shown on the attached sheet E5

Add a TVSS-1 unit to the panel P1 panel schedule. The TVSS-1 unit shall be factory installed integral to panel P1, and not take up any of the circuit breaker spaces.

**4. Sheet E3 – Electrical Details**

Replace detail #1: Electrical Distribution Diagram with the detail #1: Electrical Distribution Diagram - Revised shown on attached sheet E5.

See Addendum 3 Plans

**CHANGES TO THE SPECIFICATIONS**

**1. Section 16420 – Service Entrance, Part 2-Products**

Add the following sentence to the Enclosed Circuit Breaker article:

Provide an enclosed circuit breaker that is a current limiting type.


All Bidders must sign and return this Addendum for the bid opportunity referenced above. Failure to do so may subject the Bidder to disqualification. If a bid response has already been submitted, this Addendum shall be signed and emailed or faxed to the Purchasing Section prior to the scheduled Letting Date.

\_\_\_\_\_  
Company Name *(please print)*

\_\_\_\_\_  
Date

\_\_\_\_\_  
Signature

Sincerely,

A handwritten signature in black ink that reads "Rhonda Ruark". The signature is written in a cursive style with a large initial "R".

Rhonda Ruark, Purchasing Agent III  
Phone No. 515-239-1285  
rhonda.ruark@dot.iowa.gov